



**NOTES:**

1. CURB RETURN, GUTTER AND VALLEY GUTTER TO BE POURED MONOLITHICALLY.
2. EXPANSION JOINT MATERIAL SHALL BE 1/4" THICK PREMOLDED JOINT FILLER CONFORMING TO REQUIREMENTS OF ASTM DESIGNATION D 1751.
3. SURFACE SHALL BE ROUGH BROOM FINISH.
4. CONCRETE SHALL BE CLASS 1 OR 2.
5. CURB RETURN, GUTTER AND VALLEY GUTTER TO BE POURED MONOLITHICALLY.



# CITY OF CLOVIS

## CONCRETE VALLEY GUTTER

DWG NO.  
**ST-10**

REF.:  
STD. SPECIFICATIONS

APPROVED BY:	NO.	REVISED	BY	APPROVALS	SCALE: NTS
CITY ENGINEER <i>[Signature]</i> DATE: <i>10/29/17</i>		01-13-11	BGJ	CM <i>[Signature]</i>	DRAWN BY: JA
		05-29-12	PAA	DRU <i>[Signature]</i>	
		04-13-17	CGV	PUD <i>[Signature]</i>	SHEET 1 OF 1