



EXISTING CURB, NEW GUTTER

- NOTES:**
1. SIDEWALKS, CURBS AND GUTTERS TO BE CLASS 3 CONCRETE; EXTRUDED CURB SHALL BE CLASS 2.
 2. APPLY TACK COAT TO GUTTER PAN FACE AND EXISTING AC PRIOR TO PAVING.
 3. BROOM FINISH ON C&G AND SIDEWALK. MED. SWEAT FINISH ON SIDEWALK IS OPTIONAL OR AS DIRECTED BY THE ENGINEER.
 4. BROOM FINISH SHALL BE PERPENDICULAR TO THE PATH OF TRAVEL ON SIDEWALKS, AND PARALLEL TO THE PATH OF TRAVEL ON CURB & GUTTER.
 5. CURB & GUTTER SUBGRADE, COMPACT TO 95%. SIDEWALK SUBGRADE, COMPACT TO 90%; BEHIND DRIVE APPROACH, 95%.
 6. EXPANSION JOINT MATERIAL SHALL CONSIST OF 1/4" THICK PREMOULDED JOINT MATERIAL MEETING ASTM DESIGNATION D-1751.
 7. ALL WORK CONSTRUCTED BY THIS STANDARD SHALL BE COMPLETED IN COMPLIANCE WITH CURRENT ADA REGULATIONS. THE SIDEWALK SHALL PROVIDE A CONTINUOUS AND UNOBSTRUCTED PATH-OF-TRAVEL FOR PEDESTRIANS WITH DISABILITIES IN ACCORDANCE WITH CURRENT ADA STANDARDS.
 - 8.



CITY OF CLOVIS

CONCRETE CURB & GUTTER AND SIDEWALKS

DWG NO. **ST-5**

REF.: STD. SPECIFICATIONS

APPROVED BY:	NO.	REVISED	BY	APPROVALS	SCALE: NTS
	CITY ENGINEER <i>M. J. ...</i>	12-29-11	BGJ		CM <i>...</i>
DATE: 6/29/17		04-13-17	CGV	DRU <i>...</i>	SHEET 1 OF 1
				PUD <i>...</i>	