



**NOTES:**

1. A WELL ABANDONMENT PERMIT SHALL BE OBTAINED FROM THE CITY BUILDING DIVISION PRIOR TO PERFORMANCE OF WORK.
2. WELL ABANDONMENT OPERATIONS SHALL BE PERFORMED BY A LICENSED (C-57) WELL DRILLING CONTRACTOR IN ACCORDANCE WITH CALIFORNIA WATER RESOURCES BULLETIN #74, OR LATEST REVISION.
3. WELL CASING SHALL BE CUT OFF AT LEAST 6' BELOW GROUND LEVEL. UNCASSED WELLS SHALL BE EXPOSED AND FILLED AT LEAST 6' BELOW GROUND LEVEL.
4. LOWER PORTION OF CASSED WELLS (BELOW 20' LEVEL) SHALL BE FILLED WITH CLEAN SAND OR OTHER APPROVED NONORGANIC MATERIAL, AND SHALL BE INSPECTED PRIOR TO FURTHER WORK.
5. UPPER 20' OF A CASSED WELL OR ENTIRE LENGTH OF A TEST WELL OR UNCASSED WELL SHALL BE FILLED IN ONE CONTINUOUS POUR WITH CONCRETE CEMENT GROUT, OR OTHER IMPERVIOUS MATERIAL AS DEFINED IN "WATER WELL STANDARDS", STATE DEPARTMENT OF WATER RESOURCES, BULLETIN #74, AND INSPECTED PRIOR TO FINAL COVERING.
6. THE EXPOSED WELL AND SURROUNDING EXCAVATION SHALL BE COVERED DURING ALL PERIODS OF INACTIVITY WITH A SUITABLE COVER SUFFICIENTLY ANCHORED TO PREVENT HAZARD TO THE PUBLIC AND/OR CONTAMINATION OF THE WELL.



# CITY OF CLOVIS

DWG NO.  
**W-16**

## WATER WELL ABANDONMENT

REF: WATER WELL STDS., CALIF. WATER RESOURCES BULLETIN #74

APPROVED BY:  
  
CITY ENGINEER  
DATE: 1/17/13

NO.	REVISED	BY
	02-26-09	BGJ
	01-09-13	PAA

APPROVALS  
 CM [Signature]  
 DRU [Signature]  
 PUD [Signature]  
 BLD [Signature]

SCALE: NTS  
 DRAWN BY: JA  
 SHEET 1 OF 1