



LEGEND:

- A. METER IDLER TO PIPE THREAD ADAPTER
- B. 1" x 5" GALVANIZED PIPE INSTALLED LEVEL
- C. 1" GALVANIZED 90° ELBOW
- D. 1" GALVANIZED PIPE, LENGTH VARIES
- E. 1" DIAMETER NIPPLE
- F. 1" TO 3/4" REDUCER
- G. 3/4" DIAMETER NIPPLE
- H. 3/4" HOSE BIB (TYP.)

NOTES:

1. CONTRACTOR SHALL FURNISH AND INSTALL ALL ITEMS LISTED IN LEGEND.
2. SEE STANDARD W-5 FOR WATER SERVICE.
3. WATER SERVICE AND METER BOX INSTALLATION SHALL BE INSPECTED AND APPROVED BY CITY PRIOR TO SIDEWALK INSTALLATION.
4. ALL MATERIALS SHALL BE AS NOTED OR CITY APPROVED EQUAL.
5. A CLEAR SPACE OF AT LEAST 3" SHALL BE MAINTAINED BETWEEN SPACER ASSEMBLY (B) AND TOP OF DIRT INSIDE BOX.



CITY OF CLOVIS

DWG NO.
W-21

ANTI-SIPHON HOSE BIBB VACUUM BREAKER FOR TEMPORARY HOSE CONNECTION

REF. STD. SPECIFICATIONS SECTION 66

APPROVED BY:

CITY ENGINEER

DATE:

NO.	REVISED	BY	APPROVALS
	06-19-14	R.E.	CM DRU PUD

SCALE: NTS

DRAWN BY: REY EMPLEO

SHEET 1 OF 1