



# Clovis Fire Department

## Standard # 26

### ABOVE GROUND FLAMMABLE LIQUID TANKS

The following criteria shall be adhered to regarding the installation of all aboveground flammable liquid tanks including all waste oil or any contaminated flammable or combustible liquids.

1. No container shall exceed 1,000 gallons liquid capacity.
2. Steel tanks shall conform to Underwriters Laboratory Listing 142.
3. All containers shall be provided with double containment, with the secondary container providing 110 percent capacity of the original container.
4. All aboveground flammable liquid tanks shall have a fire protective coating of concrete or an Underwriters Laboratory listed approved fire coating (two-hour rating).
5. All aboveground combustible or flammable liquid tanks shall meet the requirements of NFPA #30.
6. All tanks shall conform to the requirements of the current adopted Uniform Fire Code.
7. Prior to installation, all tanks shall be reviewed by the Clovis Fire Department to insure conformance with adopted codes and standards.
8. All aboveground flammable liquid tanks shall have a protection post installed when accessible to vehicular movement around the tank and the tank is not in an approved planter protected by curbs.
9. All installations will require the applicant to submit plans to the Building Division which show existing parcel, existing buildings, type and brand of appliance to be installed, location of installation, and any electrical information necessary to secure a permit.
10. All tanks shall have approved warning signs.
11. All tanks shall be placed on concrete pads.
12. Submit a hazardous materials business plan to Fresno County. (see enclosed fact sheet)

Should you have any questions, please contact the Clovis Fire Department at (559) 324-2200.

Complete Containment Systems  
6735 W. Frier Drive  
Glendale, AZ 85303  
1 (800) 543-9741

Convault  
Convault Above Ground Tanks  
4200 Lester Rd.  
Denair, CA 95316  
1(800) 222-7099

Eco Vault Corporation  
Franzen Hill  
1100 North J Street  
Tulare, CA 93274  
1 (800) 655-3436

Envro-Vault  
BRE Products, Inc.  
20902 Brookhurst, Ste 207  
Huntington Beach, CA 92646  
1 (714) 965-7179 or (559) 686-0070

Fuel Master  
LRS, Inc.  
1903 Durfee Ave. South  
El Monte, CA 91733  
1 (818) 350-8040 or (213) 686-0070

Hallmark Tank Vault  
Hallmark Industries  
19113 South Hamilton Ave.  
Gardena, CA 90248

Petro Vault  
Sannipoli Corporation  
110 North Hale Ave.  
Escondido, CA 92025  
1 (800) 752-7708

Supervault  
Trusco Tank Inc.  
Fresno-Petroleum Products Division  
P.O. Box 11925  
Fresno, CA 93775  
1 (800) 800-TANK