



Clovis Fire Department

Standard #28

FIREWORKS DISPLAYS

1. At least 10 days prior to the event, the following items must be submitted to the Clovis Fire Department for consideration of approval of a public fireworks display permit in the City of Clovis.
2. Completed Public Fireworks Display application.
3. Copy of a valid Public Display license.
4. Proof of Workman's Compensation insurance.
5. Proof of Certificate of Public liability and property damage insurance of not less than one million dollars (\$1,000,000). The City of Clovis, and its officers, and employees shall be included as additional insureds. This policy shall have a deductible not to exceed \$15,000. Certificate shall provide at least 15 days prior notice of cancellation.
6. Provide a legible site plan with shoot location, fallout zone, buildings, roads and the lines behind which the audience will be restrained. Also include the location and types of barriers used to secure the display area.
7. Product performance sheets for all products used in the display shall be provided upon request.

The above items can be faxed to 559-324-2846 or delivered to 1233 Fifth St. Clovis, Ca. 93612. The application will then be returned with an approval or denial. Please call 559-324-2200 with any questions.

The following regulations shall apply:

1. The permit is not transferable.
2. A pre-show test firing may be required by the Fire Marshal.
3. All debris must land within the fallout zone, as noted on the site plan.
4. Site security is to be either arranged or provided by the applicant.
5. All displays shall have rope barriers, fences, signs or other devices to be installed around the display area to aid in crowd control.
6. All ground pieces shall be located not less than 150' from spectators or vehicles; not less than 100' from tents, canopies or membrane structures; not less than 100' from mortars' and outside of designated landing area. Exception: fixed ground pieces shall not be closer than 75' to spectators or vehicles.

7. The operator's panel is to be cleared only when the firing zone is clear.
8. A Theatrical license is required for the use of product closer than 75' to the audience.
9. Inspection and approval by the Clovis Fire Department is required prior to the display and it will not proceed unless a representative of Clovis Fire Department is present.
10. The Fire Department representative has the authority to revoke the permit at anytime prior to or during the display. The display will not continue when the permit is revoked.
11. The entire firing range shall be inspected immediately following a display and prior to allowing public access for the purpose of locating unexploded shells.
12. Within 10 days following any public display, the operator shall submit a post display report to the State Fire Marshal and provide a copy to the Clovis Fire Department.
13. No noise producing devices without visual effect allowed, such as salutes.